



Steel Palisade Medium/High Security
 17 pales per bay, 3mm thick corrugated
 pales secured to 65x50x6mm mild
 steel angle iron rails secured with CSH
 bolt and shear nut.

2no pales extended per bay into a
 concrete cill

Posts 102x44mm RSJ at 2.75m
 centres

Currently this is known as NGTS2.22
 type specification and is favoured by
 Utilites Companies and Contractors as
 the minimum standard

JB Corrie & Co. Limited

Fencing Contractors & Manufacturers

Frenchmans Road

Petersfield

Hants

GU32 3AP

Email: fencing@jbcorrie.co.uk



Tel: 01730 237100

Fax: 01730 264915

Web: www.jbcorrie.co.uk

JBC Ref.: JB Corrie

JB Corrie : JB Corrie

Drg. no.: JBC_PALISADE_NGTS_126

Scale: Not to Scale

Paper Size: A4

Drawn by & date:

Reviewed by & date:

LR

LR - 19.01.09

Description: Palisade Utilities NGTS2.22

Site: unknown

Revision history:

Notes:

1. All dimensions in mm unless otherwise indicated.